

July 17, 2017

Bob Murphy
President
MurCal
41343 12th Street West
Palmdale, CA 93551

**Re: Revised Final Certification of Stationary Natural Gas
Emission Compliance System for District Rule 4702
Compliance**
Certification Number: C-1121059

Dear Mr. Murphy:

The District is issuing a revised Final Certification under District Rule 4702 (Internal Combustion Engines) for the Stationary Natural Gas Emission Compliance (SNGEC) System described below.

The District reviewed the information provided in your application and the emissions data for internal combustion (IC) engines equipped with the SNGEC add-on emission control system consisting of the following components:

- Compliance Controls (FW Murphy) AFR (1R, 9R or 64R) air/fuel ratio controller,
- Johnson-Matthey Model Modulex B or Modulex C 3-way catalyst,
- Zirconia HEGO type oxygen sensor(s),
- Manifold Absolute Pressure (MAP) sensor, and
- Two Type K thermocouples

The initial source tests and extended use portable analyzer monitoring information submittal indicates that the SNGEC System described above is capable of satisfying the following District Rule 4702 requirements for agricultural, rich-burn, spark-ignited IC engines:

- Reducing exhaust emission levels to less than or equal to all of the following limits, corrected to 15% exhaust oxygen content: 90 ppmvd-NO_x, 2,000 ppmvd-CO, and 250 ppmvd-VOC.

The SNGEC System described above is now considered to be "District Rule 4702 Certified" for any natural gas-fueled, rich-burn, agricultural IC engine for which it has been individually designed.

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

